

Building Department TOWN HALL • 525 WASHINGTON STREET • WELLESLEY • MA 02482-5992 781-431-1019 EXT. 2228 FAX 781-283-5724

Michael T. Grant Inspector of Buildings Zoning Enforcement Officer Public Safety Officer

Erik Tardif Local Building Inspector Asst. Zoning Enforcement Officer Michael R. Sweeney Wiring Inspector

George Lessard Plumbing & Gas Inspector

Russell Wheeler Local Building Inspector Asst. Zoning Enforcement Officer

This is a guide on what the Building Department will be inspecting on your Annual Certificate of Inspection which is required by the Massachusetts State Building Code. Please follow the suggestions, including but not limited to, the list below for your inspection.

Keep all current fire suppression and fire alarm reports in a folder and
all parties involved to have access on the day of inspection.
Appoint an agent who knows the inspection process.
Have all fire suppression systems, Ansul Systems, Fire Extinguishers, etc,
tagged properly and mounted in the correct locations.
All exit signs in the proper location.
All emergency lighting operational.
All means of egress clear and unobstructed.
Any new furniture tagged with the proper fire ratings (Cal 133 for unsprinkled and Cal 117 for buildings with sprinklers).
, , , , , , , , , , , , , , , , , , , ,
Keep this list in a visible location.
All buildings with exterior bridges, walkways, fire escapes and egress
balconies will need inspection results in accordance with section
102.2.2.4 of 780 CMR 8 th Edition. Inspection results are completed every
five years.

Italicized text represents new inspections under Section 110 of the 780 CMR 8th Edition